



1. Roads / Sidewalks

- a) Grade industrial road, 45 Ave
- b) Grade back alleys
- c) Fill and level water main break excavation
- d) Sweep streets and avenues
- e) Fill potholes

2. Water/Wastewater

- a) - The town experienced 1 power failures since last report -All systems good
- b) - Continuing Covid 19 housekeeping protocols for water/wastewater facilities
- c) - Manually fill customers at truck fill due to uploading issues (now resolved)
- d) - Seasonal Bacti sample taken at G.O.'s Drive In – pre opening protocol
- e) - Annual Reservoir Engine driven pump service - Peak
- f) - Annual Lift station - Generator service- Peak
- g) - Residential meter check
- h) - Monitoring distribution flow rates
- i) - Poor internet at pumphouse
- j) - Chlorine alarms at Pumphouse on Friday Apr 16 due to high cl2 levels from Ace for Derwent reservoir tie in, cl2 levels went through alarm set point but well within safe parameters
- k) - Met with Vegreville operator for update on lead sampling plan for May – Town of Two Hills is required to take 20 samples

3. Other

- a) Replace and repair all traffic and address signs
- b) Service and repair all mowing equipment
- c) Service tractor and rotovator
- d) Service and repair street sweeper
- e) Haul all wood chips from lagoon to the golf course
- f) Weiss Mechanical certified tandem and single axel dump trucks and vac truck
- g) Gopher extermination at lift station and Geleta park
- h) Complete all service requests

