

Roads / Sidewalks

- a) Sweep all streets and avenues
- b) Fill potholes as required
- c) Repair water line break excavation
- d) Grade and pack 54 Ave between 51 St and 53 St
- e) Spectre filled all cracks on 50 Ave, 47 Ave & 53 Ave
- f) Grade back alleys

Water/Wastewater

- a) The town experienced a few power disruptions since last report - one causing the water main break
- b) Main break repaired 20 feet of poor condition cast iron main was removed and replaced with blue brute plastic and 6-inch-High max clamps - 3 Bacti samples taken and delivered to Prov Lab in Edmonton
- c) Restore residential water service as per request
- d) Continue to monitor pressure and flow rates
- e) Non payment water disconnects as per office request
- f) Sanitary Lift station generator test
- g) Manhole checks around town
- h) Engine driven pump test at water reservoir

Other

- a) Remove and repair Town signs and reinstall at golf course and fishpond
- b) Cut up old power poles and split the large blocks to clean up yard
- c) Service and repair street sweeper
- d) Mow grass and weed whip all Town property
- e) Nordic installed new brine pump in arena ice plant
- f) Repair and service grass maintenance equipment
- g) Supply and haul screened loam to the Mennonite School
- h) Fertilize and water flowers
- i) Inspect and communicate with unsightly properties
- j) Complete all service requests

Note: Public Works continues to use Covid 19 Best Practices and Standard Procedures when dealing with the public and during property entry for the performance of Water / Wastewater duties.

