



1. Roads / Sidewalks

- a) Complete base grading and packing on 51 Ave between 46 St and 49 St
- b) Apply tack oil to 51 Ave
- c) Complete back filling behind sidewalk and curb on 51 Ave
- d) Install new catch basins and drain line on 51 Ave at 48 St
- e) Grade industrial road, 52 Ave and 46 Ave

2. Water/Wastewater

- a) The Town experienced 1 ATCO scheduled power disruption and 1 power failure since last report, back up battery in control system in control panel discovered to be weak. Back up unit replaced (Nacon) and old unit refurbished with new batteries
- b) Continuing Covid-19 housekeeping protocols for water/wastewater facilities
- c) Annual THM test taken
- d) Some minor issues with air in jockey pump prv causing lead pump to act as primary until air relief valve stabilized – all systems good
- e) Last 2 lead sample results received – all test result letters completed and delivered to residents for 2021 – all samples taken were well below maximum allowable levels
- f) Annual release pond berm mowed – some small rip rap repairs required
- g) Residential sewer line augured by on call staff on weekend
- h) Monitoring distribution flow rates
- i) Water service restored to residential property as per request
- j) Towns summer employees to start June 28th (with the exception of one worker who was hired to help with road construction)
- k) The CMTA (Wayside) employee started in early June and has been watering flowers with the assistance of one AG student and has also been mowing and weed whipping Town parks and facilities

3. Other

- a) Remove old sidewalks on 45 Ave and 47A St
- b) Mow all Town grass at parks, lift station, road ditches, cemetery and both sides of old rail bed at 47 Ave
- c) Pick up and hang all flower baskets
- d) Service and repair all mowing equipment
- e) Complete all service requests

